

## **Compliance Document**

No. D 083373 0073 Rev. 00

Holder of Certificate: JIANGSU GOODWE POWER SUPPLY

**TECHNOLOGY CO., LTD.** 

No. 90 Zijin Road New District 215011 Suzhou

PEOPLE'S REPUBLIC OF CHINA

Product: Converter

**AC-coupled energy inverter with storage** 

battery system

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. For details see: www.tuvsud.com/ps-cert

**Test report no.:** 704092001922-00

**Date**, 2021-04-26

( Zhengdong Ma )

XN MA



## **Compliance Document**

No. D 083373 0073 Rev. 00

Model(s): AC-coupled energy inverter: GW5000S-BP,

GW3600S-BP

Storage battery system: L051100-A (Power Lite)

## **Parameters:**

| Farailleteis.                                  |  |                            |  |
|--|--|----------------------------|--|
| AC coupled energy inverter with storage batter | y system:  |                            |  |
| 1) Storage battery system parameters:          |  |                            |  |
| Battery Type                                   | Li-ion   |                            |  |
| Model  | Manufacturer   | Piece(s) of battery module |  |
| L051100-A (Power Lite)                         | Shenzhen<br>UZ Energy<br>Limited                         | 1-16                       |  |
| BMS firmware version                           | LM-M01A-YZ107  |                            |  |
| 2) AC-coupled inverter parameters:             |  |                            |  |
| Inverter model name                            | GW5000S-BP, GW3600S-BP                                   |                            |  |
| a) Battery input:                              |  |                            |  |
| Battery voltage range                          | d.c. 40-60V  |                            |  |
| Nominal battery voltage                        | d.c. 48V   |                            |  |
| Max. charge/discharge current                  | d.c. 75A/75A (GW3600S-BP)<br>d.c. 100A/100A (GW5000S-BP) |                            |  |
| b) AC-output (grid side):                      |  |                            |  |
| Rated output voltage                           | a.c. 230V  |                            |  |
| Rated output frequency                         | 50Hz   |                            |  |
| Rated output power                             | 3600W (GW3600S-BP)<br>4600W (GW5000S-BP)                 |                            |  |
| Max. apparent output power                     | 4050VA (GW3600S-BP)<br>5100VA (GW5000S-BP)               |                            |  |
| Max. output current                            | a.c. 16A (GW3600S-BP)<br>a.c. 22.8 (GW5000S-BP)          |                            |  |
| Displacement factor                            | -0.91+0.9  |                            |  |



## **Compliance Document**

No. D 083373 0073 Rev. 00

| AC coupled energy inverter with storage I | pattery system:                                  |  |
|---|--|--|
| c) AC-output (back-up):                   |  |  |
| Rated output voltage                      | a.c. 230V  |  |
| Rated output frequency                    | 50Hz   |  |
| Rated output power                        | 3600W (GW3600S-BP)<br>5000W (GW5000S-BP)         |  |
| Rated output current                      | a.c. 16A (GW3600S-BP)<br>a.c. 21.7A (GW5000S-BP) |  |
| d) AC-input                               |  |  |
| Rated voltage                             | a.c. 230V  |  |
| Rated output frequency                    | 50Hz   |  |
| Current (Maximum continuous)              | a.c. 32A (GW3600S-BP)<br>a.c. 40A (GW5000S-BP)   |  |
| e) Other parameters:                      |  |  |
| Protection class:                         |  |  |
| Degree of protection:                     | IP65   |  |
| Overvoltage category:                     | II (DC), III (AC)                                |  |
| Ambient temperature:                      | -25°C+60°C                                       |  |
| Firmware version                          | 0707A  |  |

Tested according to:

CEI 0-21:2019/V1:2020

